# User-Friendly, Open-System Software for Teaching Protective Relaying Application and Design Concepts

Mladen Kezunovic, Fellow, IEEE

*Abstract*—This paper describes modeling and simulation software developed specifically for teaching protective relaying application and design concepts. The emphasis was on implementing user-friendly and open-system solution that will allow an easy use and straight-forward future expansion. This is achieved by introducing new libraries of signal sources and relay elements developed for the SIMULINK environment of MATLAB. Combined with the power block set (PBS) toolbox of MATLAB, the mentioned libraries allow for a variety of studies aimed at better understanding protective relay design approaches, and related applications.

*Index Terms*—Electromagnetic transient program, faults, protective relaying, relaying schemes, time-domain simulation, transients.

#### I. INTRODUCTION

**P**ROTECTIVE relaying is a complex electrical engineering field requiring knowledge from a number of diverse engineering disciplines such as electromagnetics, circuits, power systems, computers, communications, signal processing, controls, intelligent systems, etc. Teaching protective relaying application and design concepts involves a multidisciplinary approach where the physics of the fundamentals together with diverse mathematical formulations need to be merged in a common framework. One convenient and yet powerful way is to use modeling and simulation as the common framework [1]. To be efficient, such a framework needs to be user-friendly and amenable to future expansions as the continued needs to incorporate new developments grow. This paper describes a development of the software aimed at meeting such requirements.

Recently published IEEE survey paper discussing different approaches to modeling protective relays and related power system events indicates a variety of possible software tools that may be used for this purpose [2]. Well-known software packages can be used to simulate power system faults in both the time-domain (electromagnetic transients) [3]–[5] and phasor (unbalanced steady state) [6]–[8] modes. Some of the packages have the provision for incorporating protective relay models developed by the user [9], [10] while the others have the generic relays models already included [6]–[8]. In all of the mentioned cases, it is difficult to add the modeling and simulation features to teach specific protective relaying concepts that go beyond the level of detail originally provided by the

M. Kezunovic is with the Department of Electrical Engineering, Texas A&M University, College Station, TX 77843-3128 (e-mail: kezunov@ee.tamu.edu).

Digital Object Identifier 10.1109/TPWRS.2003.814849

software. Additions of new relay models and implementations of specific fault scenarios as well as the flexibility of changing the way the models of relays and power system interact is constrained by the specific user and programming interface rules embedded in the existing software.

To facilitate the mentioned user tasks, a specialized teaching software environment is developed using a commercial software that was built to allow for flexibility in providing user interfaces and implementing custom models. The MATLAB software package with SIMULINK support and Power Block Set toolbox [11]–[14] is utilized to develop customized model libraries for teaching protective relaying concepts. This paper provides details of this development and indicates how the userfriendly interface and open-system goals are achieved.

The paper starts with discussion of the reasons for using MATLAB and associated tools. Developments of new libraries are described next. The use of the overall solution in teaching the relaying concepts is also presented. Conclusions are given at the end.

### II. MODELING PROTECTIVE RELAYS IN MATLAB

MATLAB has been selected as the programming shell for the new protective relay modeling software. Particular factors that support the selection of MATLAB are [11]–[14]

- a) *MATLAB is a de-facto standard* that already dominates the university environment and is more and more recognized in industry including the power engineering field.
- b) A flexible software structure of MATLAB comprising libraries, models, and programs enables one to integrate different model components in one package conveniently.
- c) MATLAB and its time domain solver SIMULINK create a *friendly and open system*. New models and libraries may be just added to the package without deep knowledge nor modification of the existing parts. This is very useful if the user is also involved in continued development of the software.
- d) Fast-development with MATLAB using powerful calculation and visualization means of the package enables one to expand the software quickly and efficiently without developing any extra programming tools.
- e) A wide selection of TOOLBOXes, comprehensive collections of predefined functions for solving application-specific problems, is already available with MATLAB and is likely to grow even faster in the future.
- f) Power system blockset, one of the latest extensions of MATLAB, is enabling modeling the basic components of power systems. It provides computations similar to

Manuscript received November 19, 2001; revised April 28, 2002. This work was supported in part by the National Science Foundation under Grant ECS-96-19294 and in part by EPRI under Contract WO 8618-02.

EMTP/ATP permitting modeling of both the power system and its controls in the same environment, and thus, facilitating closed-loop simulation.

#### III. BASIC SOFTWARE CONCEPT

The developed software emulates very closely the general philosophy of SIMULINK. The hardware and software elements of digital relays have been reduced to their generic models and implemented as blocks. The important issues that needed to be solved were

- how to partition the hardware and software of a relay into blocks, keeping the number of blocks at the minimum while providing maximum flexibility of simulation;
- what are the generic models of particular hardware and software blocks enabling accurate simulation;
- what is the variety of options and parameters to be implemented in particular blocks;
- what is the optimal and flexible representation of input/output signals in the relay model (the issue of connecting the blocks);

The aforementioned issues are addressed below.

## A. Partitioning a Digital Relay Blocks for Modeling

When partitioning a digital relay (i.e., selecting the blocks to be used in modeling) the objectives were

- to keep the number of blocks at minimum;
- the blocks should correspond to typical hardware and software modules of actual relays;
- the variations within a given block (digital filter, for example) should be accomplished by setting up options and input data associated with the block, not by generating new versions of the same block.

As a result, over a dozen blocks have been developed so far. They may be combined (with occasional support of the standard SIMULINK libraries) into a model of almost any digital protective relay. The detailed review of these blocks is given in Section III.

#### B. Generic Models of Relay Elements

For each block representing either a part of the relay hardware or software, complete relay or protection system, a certain generic model has been assumed. For example, the model of the front end data acquisition board (DAB) provides signal conditioning, analog filtering, and sampling. A variety of options has been provided for all of the operations included in the model. The structure of the model is fixed. The options of the block, however, enable one to modify the block significantly. For example, the analog filter may be disabled or the sampling frequency may be set very high so that the sampling gets practically disabled.

Similar choices as to the functions, structures, and options of all the blocks have been made available for the user to select.

## C. Variety of Options

A variety of options has been assigned to each block in order to model various relay designs. For example, the analog filter of the DAB can be enabled or disabled, its order can be set between

Block Parameters: DAB
- Data Adquisition Board (mask) (link)
Performs Analog filtering, signal conditioning and sampling. A single signal is the input, a buffer with the signal samples is the output. The options include analog filter enable/disable switch, type, order and cut-off frequency of the analog filter, conditioning gain, sampling frequency, number of bits, the length of the buffer.
Parameters
Disable Analog Filter
Filter approximation Bessel
Order 2
Free expression filter: numerator(descending order of s)
0
Free expression filter: denominator:
Cut-off frequency
350
Disable Vertical Resolution
Vertical Resolution: No. of bits 12
Vertical Resolution: signal range
10 16
Window size
32
Gain
1.0
Sampling frequency
60*32
Apply Revert Help Close

Fig. 1. Data entry window for the data acquisition board.

2 and 4, the cutoff frequency is a parameter, the filter's transfer function approximation can be assigned to be of four different types including a "free expression" transfer function (Fig. 1). In the same block, the sampling frequency and conditioning gain are the parameters. The vertical resolution of the A/D converter can be disabled or enabled. If enabled, the number of bits and the signal range are the parameters. This shows that each block, in order to enable modeling of various digital relays, can assume dozens of different design characteristics depending on the selected options and data.

## D. Input and Output Signals

One of the important choices when developing specialized SIMULINK blocks in general, not only for modeling protective relays, is to assume optimal representation of the input/output signals.

In SIMULINK, the signals (output–input connections between the blocks) are vectors by default [11]. The multiplexer and demultiplexer blocks are used to bundle and debundle several signals into a vector ("cable").

We followed the aforementioned approach. The following data structures are used for the signals.

- real signals including logic signals (time series of real numbers) are represented by regular SIMULINK signals;
- **complex signals** (time series of complex numbers denoting phasors and impedances) are represented by two-element vectors; the angular coordinates (magnitude, angle) have been assumed;
- **data windows** (time series of N real samples) are represented by N-element vectors with the newest sample as the first vector element.



Fig. 2. Input and output signals must fit to connect the blocks.



Fig. 3. Two copies of the bias characteristic (BC) block with two different data have different icons reflecting the data.

In order to ensure connectivity of the blocks, certain data of the interconnected blocks must be compatible. For example, the digital Fourier transform (DFT) block has its input in the form of the data window; if the block is connected to the DAB, the latter must provide the output window of at least the same length as the input window of the DFT (Fig. 2).

#### IV. PROGRAMMING ISSUES AND SOFTWARE LIBRARIES

The basic blocks (**Relay Elements**, **Tools** and **Input Signals**) have been developed as masked subsystems with s-functions performing the required operations. The following approach has been taken [11], [12]:

- The s-functions have been optimized for fast execution: using matrix algebra, avoiding loops, and other MATLAB preferred operations have been used.
- The icon of the mask has been used in a dynamic way: the icon reflects the entered data to a great extent facilitating self-documenting (Fig. 3, for example).
- The data entry mechanism of the mask has been extensively used to input the block parameters. Consequently, the locked library contains both the blocks' structures and predefined default data.
- The help link of the mask has been used to provide online help in the form of meta-text documents (html or rich text format). Fig. 4 presents an example.

The more complex blocks (**Relays** and **Protection Systems**) have been developed as appropriate connections of the basic blocks. Again, masked subsystems have been used to represent those complex structures.

Eas Character	Bias Characteristic		
Purpose	Compares its two input signals using a bias characteristic.		
Input	Two inputs feed this block. The first is the operating and the second is the restraining signal. Both signals are given in instartaneous values.		
Output	The output of this block is the result of the comparison using the bias characteristic. Its value is one if the operating signal is greater than the bias characteristic at the given restraining, otherwise it is zero.		
Dialog Box	Block Parameters: Bias Characteristic		
Parameters	Eles Cheracteristo (mask) Compares is two input signels using a bies cheracteristic. This cheracteristic is defined poir Poyspoint.		
	Porometais Bio: chanadaijuto [00:105;308;54;742;8422]		
	Sengding bequeixly (samples per cycle) [60°20		
	Apply Forest Hep Close		
Description	This block determines whether the operating signal is in the operating region at the value of restraining signal when comparing to any bias characteristics. This means that if the operating signal is greater than the bias characteristic at the given restaining, the output signal is on. Otherwise, the output is zero.		

The Bias characteristic must be entered as a two-column matrix. Each row





Fig. 5. Relay elements library.

Some blocks (file converters, for example) have been developed as MATLAB programs (m-files).

#### A. Relay Elements

This library includes models of the basic hardware and software components of a digital relay such as data acquisition board, digital filters, phasor computation algorithm, comparators, etc.

This SIMULINK library enables one to design complete relays by selecting and connecting models of appropriate elements from the library and setting the parameters.

Table I and Fig. 5 show the elements of this library.

#### B. Input Signals

This part of the software enables generating the input signals for protective relays. This includes transient modeling of the

989

 TABLE I

 SUMMARY OF THE RELAY ELEMENTS LIBRARY

Element	Description
Data	An analog input signal is filtered for antialiasing,
Acquisition	conditioned, sampled and forwarded as a data
Board	window of signal samples. The options include
(DAB)	analog filtering and A/D vertical resolution
()	enable/disable switches: type, order and cut-off
	frequency of the analog filter; range and number
	of bits of the A/D converter: conditioning gain and
	the length of the output data window.
Disital	An input signal is filtered digitally. The pro
Digital	An input signal is intered digitally. The pre-
Filler	(UR) low page bigh page band page and band
(DF)	(IR) IOw-pass, Iligit-pass, Dalid-pass and Dalid-
	stop inters of Butterworth, Bessel and Chebysnev
	Einite Impulse Eilters (EID) "Eree expression"
	digital filter can also be set
	digital litter can also be set.
Digital	An input data window is captured and the
Fourier	phasors of up to five harmonics are calculated
Transform	using the DFT technique. The options include
(DFT)	selection of the frequency of the reference (first)
	harmonic and other requested harmonics.
Basic	The voltage and current phasors are captured
Measurement	and the amplitudes, impedance components and
(BM)	power are calculated. The post-filtering may be
1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 -	applied using either mean or median filters
	(individually for each output quantity).
Differential	The block measures the impedance based on
Equation	the differential equation approach. The pre-
based	filtering using either Walsh or Fourier filters of
Impedance	selectable window length may be applied. The
Measurement	post-filtering using either mean or median filters
	may be applied. Either Euler or trapezoidal
	method of numerical differentiation may be used.
Universal	The block is fed by two signals and does a
Comparator	comparison between either the signal and a
(UC)	threshold the signal and time or the two signals
(00)	The direction of comparison may be alternated
	and the standard time characteristics are
	included.
7000	The block is fed by the registered and reactered
Comparator	values and emulates four forward impedance
(70)	zones and a reverse one Either the mho or
(20)	"froe-avoracsion" shapes may be set
	nee-expression shapes may be set.
Riggering	The block is fed by the data window of a signal
element	and acts as a transient detector. The
(TR)	implemented methods include sample-to-sample,
	cycle-to-cycle and value-to-threshold checking.
Symmetrical	The block is fed by three phase signals and
Components	produces three symmetrical components signals.
(SC)	Either phasors or instantaneous values are
	utilized.
Vector Group	The block captures instantaneous values of six
Compensator	phase currents of a three-phase two-winding
for two-	transformer and computes the differential and
winding	restraining currents. The parameters include the
transformers	CT ratios, transformer rated voltages, connection
(VG-2)	type and vector group.
<u>VG 2</u>	Similar to VG 2 but for three winding
vG-3	Similar to VG-2, but for three-winding
Bias	The block is fed by the operating and restraining
Characteristic	signal and applies a "free-expression" (point by
(BC)	I point defined) bias characteristic.

 TABLE II

 SUMMARY OF THE INPUT SIGNALS LIBRARY

Sub-Category	Elements	Structure
Signal Generators	General specification generator, limited frequency spectrum generator, phasor generators, etc.	Library
Data File Converters	ATP to MATLAB, COMTRADE to MATLAB, DFR to MATLAB	Programs
Power System Transient Model	Power System Blockset, Instrument Transformers, internal fault models	Libraries



Fig. 6. Input signals library (signal generators only).



Fig. 7. Window of the phasor display block (phase angles in degrees).

SIMULINK libraries (such as the power system blockset or models of instrument transformers) and SIMULINK blocks (such as specialized signal generators).

Table II provides a brief summary of this class while Fig. 6 shows some of the SIMULINK blocks.

## C. Tools

This library contains elements that facilitate the analysis and testing procedures.

The phasor display is perhaps the best example (Fig. 7). This block can be fed by up to six phasors (multiplexed into a single

power system for closed-loop simulation (link to ATP and MATLAB's power system blockset) as well as the analytical way of generating the signals. In addition, a file format conversion for data from major transient file formats (COMTRADE [14] and MATLAB's native format) is also provided. This part of the software contains MATLAB programs (file converters),

input vector). It displays them in both the graphical and numerical forms. The block can be disabled (present in the model but not active). The display can be of the transient type (the plot refreshed every given time interval) or of the steady state type (the values are displayed when the simulation terminates). To use the display, one puts its block in the model, connects the input, and sets required options. Once the simulation is started and the block is set to active, a new window pops up and the plot is created.

#### D. Relays and Protection Systems

These two libraries contain preset models of complete digital relays and protection terminals such as overcurrent, impedance, and differential relays.

Those models are composed from the blocks of the **Relay Elements** library and the general SIMULINK libraries. Some of the relay models emulate actual relays to the extent possible using the publicly available design details.

Figs. 8–10 present an example of a three-phase overcurrent relay featuring three-phase instantaneous and inverse-time elements as well as instantaneous residual overcurrent element. In this model:

- The DAB block is used to model analog filters, signal conditioners, and the A/D converter (Fig. 10). The following parameters of the filters (design parameters are entered in this block: order, cutoff frequency, type of approximation), signal conditioner (gain) and the A/D converter (sampling rate, number of bits, signal range).
- The digital filter (DF) block is used to filter the phase currents digitally. Type of the filter, its order, and cutoff frequencies are specified in this block (Fig. 10).
- The symmetrical components (SC) block is used to extract the residual current from the phase currents (Fig. 9).
- The universal comparator (UC) block is used to specify both the instantaneous and time-delayed overcurrent characteristics. The relay settings are entered here (Figs. 9 and 10).
- The standard SIMULINK elements are used to deal with the trip and target signals.

As seen from the figures, this model can be assembled from the available libraries in a very convenient and quick way. Modifications of its structure and parameters are very easy. Once developed, the model can be "zoomed-out" to a subsystem [11], get assigned a name and icon, and may be included into a library of **Relays** as a new block (Fig. 8). This approach speeds-up the model development phase significantly.

In the same way, a larger structures of **Protection Systems** are built out of **Relays** and **Relay Elements**.

Protective relays or protection systems modeled using the developed libraries can be tested with the input signals from the following sources:

- signal generators of the input signals library;
- power system blockset of MATLAB;
- ATP output files via the developed file converter;
- COMTRADE transient data files via the developed file converter.



Fig. 8. Overcurrent relay model (IA, IB, IC-input currents, TRIP\_51, TRIP\_50, TRIP\_RES-targets).



Fig. 9. Content of the relay model of Fig. 8.



Fig. 10. Content of the phase A channel.

The results of testing (in terms of transient data) can be saved in a native MATLAB format or in COMTRADE via the developed output filter.

## V. TEACHING EXAMPLES

Having the package developed and capable of performing emulation of both the power system and related protective relays, its usage in education and training needs to be carefully designed and planned.

This section presents teaching examples of different complexity levels and different perspectives.

## A. Symmetrical Components and Sequence Networks

Fig. 11 presents a predefined SIMULINK model for the topic of symmetrical components and networks within the class *Input Signals*. In this model

1) the three-phase one-machine power system is set-up using the power system blockset;



Fig. 11. Teaching example for symmetrical components and networks.

- three sequence networks are created and connected to reflect the type and location of a fault occurring in the three-phase system;
- 3) measuring devices are placed in both the original system and sequence networks to facilitate comparison between the signals from the original three-phase system and sequence networks. This includes ideal voltage transformers, a converter from the phase values to symmetrical components, and displays.

The configuration and parameters of the entire model may be changed by cut-and-paste and drag-and-drop manipulations with the icons.

The student assignments for this example include

- selecting the three-phase system in terms of parameters and connections (especially the way of grounding the neutral points); changing the type, parameters, and location of the fault and observing the values and relations between the symmetrical components (studying the power system in unsymmetrical fault states);
- editing the original three-phase system, changing the fault type and parameters and editing the sequence component networks in terms of parameters and connections to reflect the changes in the original system. Comparing the results from the original system and its sequence-network-based "solver" (learning how to use sequence networks).
- By this example the students learn
- a) the relation between the type and parameters of a fault and values of symmetrical components;
- b) the rules of using the sequence networks for analysis of three-phase systems.

### B. Impedance Relaying Principle

Fig. 12 introduces a predefined SIMULINK model for the topic of impedance relaying principle within the class *Relaying Principles*. The model consists of

1) A single-phase model of a two-machine three-line power system with models of the fault and instrument transformers.



Fig. 12. Teaching example for impedance relaying principle.

- 2) Measuring blocks estimating the voltage and current phasors as well as impedance components.
- 3) Zone comparators checking the impedance location against three impedance zones.
- 4) Displaying elements.

The student assignments for this example include

- placing faults at different locations and observing the value of the impedance. Introducing the ideas of a *relaying point*, a *protected line*, and *impedance seen* by the relay;
- simulating faults at the far end busbar with nonzero fault resistance and different prefault power flows. Explaining the in- and out-feed effects. Recommending the relay settings;
- simulating faults at the relaying point. Recommending the relay settings. Explaining the need for a directional element;
- setting the first zone of the relay. Testing the relay. Introducing the *sensitivity* and *selectivity* concepts;
- simulating external faults. Understanding the idea of a *back-up protection*. Setting the second and reverse zones.
- By this example, the students learn
- a) the basics of the impedance relaying principle;
- b) certain relay design issues;
- c) basics of impedance relay setting.

The two examples were successfully utilized in an undergraduate course at Texas A&M University in the form of a 2-h supervised laboratory exercises and take-home assignments.

## C. Analog Filtering and Sampling

Fig. 13 presents a predefined SIMULINK model for the topics of analog filtering, signal conditioning, and sampling within the class *Design Principles*. This model consists of the DAB (see Table I) and few auxiliary elements.

The student assignments for this example include

• simulating and explaining the aliasing phenomenon in both the time and frequency domains;



Fig. 13. Teaching example for analog filtering and sampling.

- selecting an analog filter. Investigating its effects on both the noise and information;
- selecting the sampling frequency;
- simulating and explaining the phenomenon of vertical resolution of an A/D converter;
- testing the complete front-end part of a digital relay with analytical and EMTP-generated signals.

This example was successfully utilized in the short-course activities at Texas A&M University in the form of computerassisted lecture and a supervised hands-on laboratory exercise.

#### VI. CONCLUSIONS

Discussion given in the paper explains the following major outcomes of this development.

- The use of MATLAB and SIMULINK has enabled user friendly, open-system environment.
- The user friendly features are facilitated with the use of a simple drag-and-drop and cut-and-paste approach to building the exercises out of predefined library elements.

• The open-system capability is enhanced through possibility of adding newly developed library elements to the existing MATLAB or the new customized protective relaying libraries.

#### ACKNOWLEDGMENT

Dr. B. Kasztenny and Dr. Z. Galijasevic are acknowledged for a significant contribution to this development while they were at TAMU as Research Staff.

#### REFERENCES

- M. S. Sachdev, M. Nagpal, and T. Adu, "Interactive software for evaluating and teaching digital relaying algorithms," *IEEE Trans. Power Syst.*, vol. 5, pp. 346–352, Feb. 1990.
- [2] P. G. McLaren, C. Henville, V. Skendzic, A. Girgis, M. Sachdev, G. Benmouyal, K. Mustaphi, M. Kezunovic, L. Kojovic, M. Meisinger, C. Simon, T. Sidhu, R. Marttila, and D. Tziouvaras, "Software models for relays," *IEEE Trans. Power Delivery*, vol. 16, pp. 238–246, Apr. 2001.
- [3] Alternative Transient Program (ATP) Rule Book, CanAm EMTP User Group, Portland, OR, 1992.
- [4] EMTP Reference Manual, BPA, 1986.
- [5] EMTDC User's Manual, Manitoba HVDC Resource Center, 1996.
- [6] CAPE User's Manual, Electrocon Int., 1997.
- [7] EUROSTAG Software, Release Notes, Ver. 4.1, Tractabel-EDF, 2000.
- [8] ASPEN User's Manual, ASPEN, Inc., 1995.
- [9] C.-H. Kim, M.-H. Lee, R. K. Agarwal, and A. T. Johns, "Educational use of EMTP MODELS for the study of a distance relaying algorithm for protecting transmission lines," *IEEE Trans. Power Syst.*, vol. 15, pp. 9–15, Feb. 2000.
- [10] R. W. Wall and B. K. Johnson, "Using TACS functions within EMTP to teach protective relaying fundamentals," *IEEE Trans. Power Syst.*, vol. 12, pp. 3–8, Feb. 1997.
- [11] Using MATLAB, The MathWorks, Inc., 1999.
- [12] Using Simulink, Version 3, The MathWorks, Inc., 1990.
- [13] Power System Blockset User's Guide, Version 1, The MathWorks, Inc., 1999.
- [14] Common Format for Transient Data Exchange (COMTRADE) for Power Systems, Guides and Standards for Protective Relaying Systems, IEEE Standard C 37.111-1991, 1995.

**Mladen Kezunovic** (S'77–M'80–SM'85–F'99) is the Eugene E. Webb Professor and Director of Electric Power and Power Electronics Institute at Texas A&M University, College Station, where he has been since 1987. His main research interests are digital simulators and simulation methods for relay testing as well as application of intelligent methods to power system monitoring, control, and protection.

Dr. Kezunovic is a Fellow of IEEE and member of CIGRE-Paris.